# Testing Report - $PM_{2.5}$ Base Testing Clarity Node-S

This report reflects the v2.1 Global PM<sub>2.5</sub> Calibration performance

### Roosevelt, UT

Utah Department of Environmental Quality




August 2024—October 2024


#### Deployment Details


Testing Organization and Site Information						
Testing organization (Name, Organization type, Contact website)	Utah Department of Environmental Quality  Roosevelt Roosevelt, UT  40.29, -110.01  49-013-0002					
Testing location (City, State, Latitude and Longitude)						
AQS site ID						
Sampling timeframe (MM-DD-YY)	08-10-24 to 10-23-24					
Sensor data source	Clarity Cloud					
Reference data source	PM <sub>2.5</sub> : AirNow API Meteorological: AirNow-Tech					


Sensor Information							
Manufacturer, model	Clarity Node-S						
Device firmware version	2.4.1.01						
Sampling time interval	1-hour						
Sensor serial numbers	AGGQYYCH	A3XM6GX4	AFQV64HN				
	☐ No Issues						
	Clarity Node-S						
Issues encountered during deployment?	2.4.1.01						


FRM/FEM Information							
Manufacturer, model, designation	Thermo Scientific Model 5030i SHARP VSCC FEM						
Sampling time interval	1-hour						
Date of calibration	-						
Date of flowrate verification check	08-29-24 08-29-24 (bi-annual audit) 09-24-24 10-25-24						
Description, date(s) of maintenance activities	-						











# Testing Report - $PM_{2.5}$ Base Testing Clarity Node-S

This report reflects the v2.1 Global PM<sub>2.5</sub> Calibration performance

## Roosevelt, UT

Utah Department of Environmental Quality



August 2024—October 2024

#### **Tabular Statistics**

Sensor-FRM/FEM Correlation

	Bias and Linearity						Data Quality			
	R <sup>2</sup>		Slope		Intercept (μg/m³)		Uptime (%)		Number of paired sensor and FRM/FEM concentration values	
	1-Hour •••	24-Hour ●●●	1-Hour ●●●	24-Hour ●●●	1-Hour ●●●	24-Hour ●●●	1-Hour •••	24-Hour ●●●	1-Hour	24-Hour
Metric Target Range	≥ 0.70	≥ 0.70	1.0 ± 0.35	1.0 ± 0.35	-5 ≤ b ≤ 5	-5 ≤ b ≤ 5	75%*	75%*	-	-
Sensor AGGQYYCH	0.95	0.98	1.12	1.26	1.02	0.03	100	100	1787	75
Sensor A3XM6GX4	0.95	0.98	1.11	1.24	0.90	-0.10	100	100	1790	75
Sensor AFQV64HN	0.93	0.97	1.11	1.24	0.94	-0.04	100	100	1790	75
Mean	0.94	0.98	1.11	1.25	0.95	-0.03	100	100	1789	75

	Error					
		1SE /m³)	NRMSE (%)			
	1-Hour ★	24-Hour ★	1-Hour ☆	24-Hour ☆		
Metric Target Range	≤ 7.0	≤ 7.0	≤ 30.0	≤ 30.0		
Deployment Value	3.6	3.1	45.2	39.3		

Device-specific metrics (computed for each sensor in evaluation)

- 000 Metric value for none of devices tested falls within the target range
- •00 Metric value for one of devices tested falls within the target range
- ●●○ Metric value for two of devices tested falls within the target range
- ••• Metric value for three of devices tested falls within the target range

Single-valued metrics (computed via entire evaluation dataset)

☆ Indicates that the metric value is not within the target range

★ Indicates that the metric value is within the target range

#### Sensor-Sensor Precision

	Prec	ision (between	Data Quality			
	CV (%)		SD (μg/m³)		Number of concurrent sensor concentration pairs	
	1-Hour ★	24-Hour ★	1-Hour ★	24-Hour ★	1-Hour	24-Hour
Metric Target Range	≤ 30.0	≤ 30.0	≤ 5.0	≤ 5.0	-	-
Deployment Value	5.3	2.3	0.5	0.2	1789	75

# Testing Report - $PM_{2.5}$ Base Testing Clarity Node-S

This report reflects the v2.1 Global PM $_{\scriptscriptstyle 2.5}$  Calibration performance

### Roosevelt, UT

Utah Department of Environmental Quality



August 2024—October 2024

### Sensor-FRM/FEM Scatter Plots

